

Annual Drinking Water Quality Report

Cherry Valley

IL2010050

For the period of January 1 to December 31, 2007

This report is intended to provide you with important information about your drinking water and the efforts made by the Cherry Valley water system to provide safe drinking water. The source of drinking water used by Cherry Valley is ground water. For more information regarding this report, contact: Joe Caveny at 815-332-3441. Este informe contiene informacion muy importante sobre el agua que usted bebe. Traduzcalo o hable con alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally - occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV / AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA / CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Source Water Assessment Availability.

A Source Water Assessment summary is included below for your convenience.

Based on information obtained in a Well Site Survey published in 1989 by the Illinois EPA, several potential sources are located within 1,000 feet of the wells.

The Illinois EPA has determined that the Cherry Valley Community Water Supply's source water is not susceptible to contamination. This determination is based on a number of criteria including; monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and available hydrogeologic data on the wells.

Furthermore, in anticipation of the US EPA's proposed Ground Water Rule, the Illinois EPA has determined that the Cherry Valley Community Water Supply is not vulnerable to viral contamination. This determination is based upon the evaluation of the following criteria during the Vulnerability Waiver Process: the community's wells are properly constructed with sound integrity and proper siting conditions; a hydraulic barrier exists which should prevent pathogen movement; all potential routes and sanitary defects have been mitigated such that the source water is adequately protected; monitoring data did not indicate a history of disease outbreak; and the sanitary survey of the water supply did not indicate a viral contamination threat. Because the community's wells are constructed in a confined aquifer, which should prevent the movement of pathogens into the wells, well hydraulics were not considered to be a significant factor in the susceptibility determination. Hence, well hydraulics was not evaluated for this system ground water supply. The Illinois Environmental Protection Act provides minimum protection zones of 200 feet for your wells. These minimum protection zones are regulated by the Illinois EPA. To further reduce the risk to source water, the Facility has implemented a wellhead protection program, which includes the proper abandonment of potential routes of groundwater contamination and correction of sanitary defects at the water treatment facility. This effort resulted in the community water supply receiving a special exception permit from the Illinois EPA which allows a reduction in monitoring. The outcome of this monitoring reduction has saved the community considerable laboratory analysis costs.

To further minimize the risk to the facility's groundwater supply, the Illinois EPA recommends that three additional activities be assessed. First, the water supply may wish to enact a "maximum setback zone" ordinance. These ordinances are authorized by the Illinois Environmental Protection Act and allow county and municipal officials the opportunity to provide additional protection up to a fixed distance, normally 1,000 feet from their wells. Second, the water supply staff may wish to revisit their contingency planning documents. Contingency planning documents are a primary means to ensure that, through emergency preparedness, a community will minimize their risk of being without safe and adequate water. Finally, the water supply staff is encouraged to review their cross connection control program to ensure that it remains current and viable. Cross connections to either the water treatment plant (for example, at bulk water loading stations) or in the distribution system may negate all source water protection initiatives provided by the community.

2007 Regulated Contaminants Detected

Lead and Copper Definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALG's allow for a margin of safety.

LEAD and COPPER Date sampled 8/12/2004

Corrosion from household plumbing system
Erosion of natural deposits

Lead	Lead Action	Lead 90 th	# Sites Over	Copper	Copper Action	Copper 90 th	# Sites Over
MCLG	Level (AL)	Percentile	Lead AL	MCLG	Level (AL)	Percentile	Copper AL
0 ppm	15 ppb	< 5 ppb	1	1.3 ppm	1.3 ppm	0.283 ppm	0

Water Quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the Maximum Contaminant Level Goal as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

mg/l: milligrams per litre or parts per million - or one ounce in 7,350 gallons of water.

ug/l: micrograms per litre or parts per billion - or one ounce in 7,350,000 gallons of water.

na: not applicable.

avg: Regulatory compliance with some MCLs is based on running annual average of monthly samples.

Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water.

Maximum Residual Disinfectant Level (MRDLG): The level of disinfectant in drinking water below which there is no known or expected risk to health. MRDLG's allow for a margin of safety.

<u>Regulated Contaminants</u>	Highest	Range of		Unit of	MCGL	MCI	Violation?
	Level	Levels	Levels				
<i>Likely Source of Contaminant</i>	Found	Detected	Measure				
<u>Disinfection & Disinfection By-Products</u>							
CHLORINE	0.6	n/a	ppm	MRDLG=4	MRDL=4	No	
Collection Date (12/31/2007)							
Water additive used to control microbes							

HAA5 [Total Haloacetic Acids] Collection Date (6/7/2007) By-product of drinking water chlorination	2	n/a	ppb	n/a	60	No
<u>Inorganic Contaminants</u>						
BARIUM Collection Date (7/20/2006) Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	0.24	0.16-0.24	ppm	2	2	No
FLUORIDE Collection Date (7/20/2006) Erosion of natural deposits; Water additive which promotes Strong teeth; Discharge from fertilizer and aluminum factories.	0.83	0.8-0.83	ppm	4	4	No
NITRATE (As N) Collection Date (10/4/2007) Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	0	n/a	ppm	10	10	No
<u>Radioactive Contaminants</u>						
	<i>Highest Level Found</i>	<i>Range of Levels Detected</i>	<i>Unit of Measure</i>	<i>MCGL</i>	<i>MCL</i>	<i>Violation?</i>
ALPHA EMITTERS (Adjusted) Collection Date (1/4/2007) Erosion from naturally occurring deposits.	2.70	n/a	pCi/L	0	15	No
COMBINED URANIUM Collection Date (1/4/2007) Erosion from naturally occurring deposits.	0.2	n/a	ppb	0	30	No
COMBINED RADIUM Collection Date (4/5/2007) Erosion from naturally occurring deposits.	6	3.9-6	pCi/L	0	5	No
ALPHA EMITTERS Collection Date (4/5/2007) Erosion from naturally occurring deposits.	3.4	2.5-3.4	pCi/L	0	15	No
<u>State Regulated Contaminants</u>						
IRON Collection Date (4/5/2007) Erosion from naturally occurring deposits.	890	0.04-890	ppb	n/a	1000	No
MANGANESE Collection Date (7/20/2006) Erosion from naturally occurring deposits;	15	6-15	ppb	n/a	150	No
SODIUM Collection Date (7/20/2006) Erosion from naturally occurring deposits; Used in water softener regeneration	6.2	4.2-6.2	ppm	n/a	n/a	No
ZINC Collection Date (7/20/2006) Erosion from naturally occurring deposits; Discharge from metal factories	18	0-18	ppb	n/a	5000	No

Iron is not currently regulated by the USEPA. However, the State has set a MCL for these contaminants for supplies serving a population of 1000 or more.

Manganese is not currently regulated by the USEPA. However, the State has set a MCL for these contaminants for supplies serving a population of 1000 or more.

There is not a state or federal MCL for **Sodium**. Monitoring is required to provide information to consumers and health officials that are concerned about sodium intake due to dietary precautions. If you are on a sodium-restricted diet, you should consult a physician about this level of sodium in the water.

The state requires monitoring of certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Therefore, some of this data may be more than one year old.



806 E. State Street
Cherry Valley, IL 61016

Presorted
Standard
U.S. Postage
PAID
Cherry Valley IL
Permit No. 45